

Fire Application #343623 - FIRE ALARM PANEL UPGRADE

[illegible]



CITY OF KIRKLAND



Fire Application #343623 - FIRE ALARM PANEL UPGRADE

Project Contact

Company Name: AAA FIRE & SAFETY, INC

Name: George Washburn

Email: George@aaafire.com

Address: 3013 3rd Ave N

Phone #: 206-284-1721

Seattle WA 98109

Project Type

Nonresidential

Activity Type

Alteration

Scope of Work

Fire Alarm

Project Name: FIRE ALARM PANEL UPGRADE

Description of Work: INSTALL ADDRESSABLE FACP. RELOCATE TOWER FA CIRCUITS TO NEW PANEL.
ADDRESS CIRCUITS BY ZONE MODULE.

Project Details

System Information

This is a modification or addition to an existing system

Fire System Counts

Number of Devices 13

Valuation

Fair Market Value of Work \$36,000